

# IMPORTANT NOTICE

This liner meets international requirements for potable tank lining. It has been tested by the Australian Water Quality Centre, and certified to AS 4020 (Int)-1994.

If initially filled to only a shallow level, there may be a short term "plastic" taste associated with the water. While not harmful, it can be avoided with a quick clean:

1. Once the liner is fitted to the tank, use a soft broom or mop and a small amount of mild soap (eg: liquid Softly) to wash down the inside surface of the tank (walls and floor).
2. Rinse well (with the same soft broom or mop) and a small quantity of clean water.
3. Drain the tank then fill with fresh water to the required level - the higher the better.

Note: If the tank is initially filled with only a small quantity of water to hold the liner in place (eg: while house construction is completed), this water should be drained before commencing this procedure.

G:\corel\forms\instruct8a\_2009.cdr

© ABGAL Pty. Ltd. 2006



Freecall 1800 077 533 | Email [us@abgal.com.au](mailto:us@abgal.com.au) | Fax 07 3803 9099  
PO Box 1566 Browns Plains BC Qld 4118 | [www.abgal.com.au](http://www.abgal.com.au)  
Australia's largest manufacturer of premium liners & covers... since 1976!